

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7300-1483:157 Page 1 of 1

CATEGORY: Misc. Device/Control Unit Accessories

LISTEE: Mirtone, 90 Fieldstone Ct., Cheshire, CT 06410
Contact: Brad Miller (888) 649-9827 FAX (203) 699-3108

DESIGN: Model FSRZI-A remote zone indicator, Model FSRSI remote system indicator and Model FSRRM remote relay module. Models FSAT1, FSAT2, FSAT3 and FSAT4 nylon wall plates. Model FSRRM-S11span track mount for FSRRM. Models EOL-1.1KL and EOL-3.6KL end of line resistors. Model CTM4.7 city tie module. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: Primary Operating Supply: 21-25VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as control unit accessories for use with separately listed compatible fire alarm control units. For indoor use only.

XLF: 7300-1591:103

1-24-2003KK



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 18, 2003

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager